



**GeneralAire® Models DH75 & DH100 Wi-Fi Dehumidifiers**  
LCD Touch Screen & Wi-Fi Control

**Spec Sheet**

DH75 (5333) & DH100 (GFI #5334)		
Capacity	Up To 75 Pints Per 24 Hours @ 80°F / 27°C - 60% RH	Up To 100 Pints Per 24 Hours @ 80°F / 27°C - 60% RH
Weight (Pounds)	58	65
Dimensions (Inches)	12.75 H x 12.6 W x 21 D	15.75 H x 12.6 W x 21 D
Control	LCD Touch Screen Display With Wi-Fi	
AFCI Power Cord (meets latest in electric safety standards)	✓	✓
Power Supply	120VAC, 60Hz	120VAC, 60Hz
Energy Factor (liters/kwh)	2.0	1.86
Current Draw (Amps)	6.2	8.8
Air Flow (CFM)	180	220
Inlet Air Operating Temperature	50°F - 90°F / 10°C - 32°C	
Control Board Display Temperature	-4°F - 158°F operating / -22°F - 176°F storage -20°C - 70°C operating / -30°C - 80°C storage	
Filter Dimensions (Inches)	MERV 11 Pleated Filter GFI #7143 10 x 12 x 1 Replace Every 6 Months	MERV 11 Pleated Filter GFI #7144 12 x 12 x 1 Replace Every 6 Months
Cabinet Insulation	Foil-faced fiberglass 1/2" thick & closed cell foam	
Duct Connections (Inches)	8 Diameter (Inlet & Outlet)	10 Diameter (Inlet & Outlet)
Drain Pan	Heavy Duty, Injection Molded	
Noise (dB)	Less Than 55 (ducted)	
Warranty (Years)	Five	



- Hanging kits available separately
- Low voltage adapter included



**AFCI Power Cord**

*The latest in electrical safety standards!*



Tested to ANSI/UL STD 474, and to Can/CSA Std C22.2 No. 92-197 and applicable sections of ANSI/UL STD 1995.



Designed & Assembled in Michigan, USA

**Breathe Healthier**



General Filters, Inc.  
43800 Grand River Avenue  
Novi, Michigan 48375  
Toll Free: (866) 476-5101  
www.generalaire.com



Canadian General Filters, Ltd.  
400 Midwest Rd.  
Toronto, ON M1P3A9 Canada  
Toll Free: (888) 216-9184  
www.cgfproducts.com






**GENERAL FILTERS**  
INCORPORATED

**Dehumidifiers**  
Residential Whole-House (GFI #5333 & 5334)

**GeneralAire® Models DH75 & DH100 Wi-Fi Dehumidifiers**  
LCD Touch Screen & Wi-Fi Control

**Spec Sheet**

**Residential Whole-House Dehumidifier**



**Maintenance**

Maintenance of your new GeneralAire® Dehumidifier is minimal:

- Replace the MERV 11 pleated filter once every 6 months.
- Do not operate your dehumidifier without a filter.

GFI #7143  
for DH75



GFI #7144  
for DH100



See installation manual for instructions on how to download and use the APP.

**Breathe Healthier**



General Filters, Inc.  
43800 Grand River Avenue  
Novi, Michigan 48375  
Toll Free: (866) 476-5101  
www.generalaire.com



Canadian General Filters, Ltd.  
400 Midwest Rd.  
Toronto, ON M1P3A9 Canada  
Toll Free: (888) 216-9184  
www.cgfproducts.com

Last Updated: 8-2018

Download online at: [www.generalfilters.com/literature/spec/submittal](http://www.generalfilters.com/literature/spec/submittal). All information subject to change without notice.

PURE MICHIGAN®